



1. HYDRANT MUST BE FULLY RESTRAINED FROM TEE TO HYDRANT. USE RETAINER GLAND AT MECHANICAL JOINTS AND HARNESS ON PUSH ON PIPE PER CITY SPECIFICATION.
2. JOINT RESTRAINT IS NOT REQUIRED ON THE RUN OF THE TEE UNLESS THE TEE FALLS WITHIN THE RESTRAINED LENGTH REQUIREMENT OF ANOTHER FITTING.
3. FOR TEST PRESSURES AND LAYING CONDITIONS SEE SECTION ON GENERAL NOTES FOR USE OF RESTRAINED JOINT LENGTHS.